

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 06 月 23 日

报出日期: 2017 年 06 月 23 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S171195(青原)	15	13.1	0	含少许异物	25	7.01	2.24	0.32	--	150	>2419.6	1.28	0.10	--	>200.5
S171196(青出)	<5	0.136	0	无	25	7.11	0.88	<0.01	--	0	0	<0.05	0.04	0.53	0
S171197(荔原)	25	34.5	0	含少许异物	25	7.13	3.12	0.12	--	230	>2419.6	1.09	0.06	--	>200.5
S171198(荔出)	<5	0.082	0	无	25	6.83	0.80	0.01	--	0	0	<0.05	0.03	0.16	0
S171199(金原)	25	22.9	0	含少许异物	25	6.86	3.36	0.09	--	180	>2419.6	0.74	0.08	--	>200.5
S171200(金出)	<5	0.086	0	无	25	6.84	1.04	0.01	--	0	0	<0.05	0.03	0.13	0
GB3838-2002（Ⅲ）					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异昧	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1~0.1	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)						说明								

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制