

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 07 月 16 日

报出日期: 2017 年 07 月 16 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S171354(青原)	25	23.6	0	含少许异物	25	6.82	2.96	0.12	--	240	1986.3	0.67	0.07	--	200.5
S171355(青出)	<5	0.200	0	无	25	6.81	0.80	<0.01	--	0	0	<0.05	<0.02	0.50	0
S171356(荔原)	40	113	0	含少许异物	25	6.74	3.04	0.15	--	410	1986.3	1.61	0.12	--	200.5
S171357(荔出)	<5	0.098	0	无	25	6.58	0.96	0.01	--	0	0	<0.05	<0.02	0.22	0
S171358(金原)	30	63.4	0	含少许异物	25	6.73	2.56	0.17	--	350	2419.6	1.11	0.08	--	165.2
S171359(金出)	<5	0.200	0	无	25	6.70	0.96	0.01	--	0	0	<0.05	<0.02	0.19	0
GB3838-2002 (III)					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异味	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1-0.5	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)						说明								

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制