

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 08 月 04 日

报出日期: 2017 年 08 月 04 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S171491(青原)	15	13.4	0	含少许异物	25	7.04	2.08	0.11	--	180	>2419.6	0.35	0.02	--	129.8
S171492(青出)	<5	0.118	0	无	25	6.96	0.88	<0.01	--	0	0	<0.05	<0.02	0.51	0
S171493(荔原)	35	34.7	0	含少许异物	25	6.86	2.00	0.15	--	92	>2419.6	0.73	0.04	--	>200.5
S171494(荔出)	<5	0.107	0	无	25	6.77	0.80	0.01	--	0	0	<0.05	0.03	0.17	0
S171495(金原)	25	28.3	0	含少许异物	25	6.90	2.16	0.18	--	67	1986.3	0.77	0.04	--	>200.5
S171496(金出)	<5	0.145	0	无	25	6.74	0.80	0.01	--	0	0	<0.05	0.02	0.15	0

制表：

校对:

签发:

水质第14表
海南省城镇供水协会制