

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 09 月 22 日

报出日期: 2017 年 09 月 22 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S171829(青原)	25	9.53	0	含少许异物	25	7.05	2.24	0.07	--	220	>2419.6	0.33	0.04	--	>200.5
S171830(青出)	<5	0.126	0	无	25	7.02	1.04	0.01	--	0	0	<0.05	<0.02	0.50	0
S171831(荔原)	30	41.2	0	含少许异物	25	7.07	2.80	0.17	--	240	>2419.6	0.89	0.04	--	>200.5
S171832(荔出)	<5	0.113	0	无	25	6.90	0.88	<0.01	--	0	0	<0.05	<0.02	0.15	0
S171833(金原)	30	62.4	0	含少许异物	25	6.98	2.88	0.18	--	200	>2419.6	1.01	0.04	--	>200.5
S171834(金出)	<5	0.196	0	无	25	6.82	0.72	0.01	--	0	0	<0.05	<0.02	0.20	0

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制