

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 10 月 10 日

报出日期: 2017 年 10 月 10 日

单位： 三亚中法供水有限公司

										报告日期：2021年10月16日					
项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S171952(青原)	25	6.95	0	含少许异物	26	7.08	2.40	0.04	--	110	1413.6	0.38	0.04	--	>200.5
S171953(青出)	<5	0.093	0	无	26	6.96	0.88	0.01	--	0	0	<0.05	<0.02	0.50	0
S171954(荔原)	40	26.6	0	含少许异物	26	6.78	2.32	0.22	--	170	>2419.6	1.27	0.06	--	>200.5
S171955(荔出)	<5	0.164	0	无	26	6.81	0.64	0.02	--	0	0	<0.05	0.03	0.16	0
S171956(金原)	30	28.2	0	含少许异物	26	6.86	2.08	0.34	--	160	1732.9	0.93	0.04	--	>200.5
S171957(金出)	<5	0.131	0	无	26	6.83	0.56	0.02	--	0	0	<0.05	0.02	0.25	0

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制