

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 10 月 13 日

报出日期: 2017 年 10 月 13 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	臭和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	铁	氨氮	余氯	二氧化氯	菌落总数	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL
S171974(青原)	25	57.6	0	含少许异物	26	7.13	3.12	0.38	0.14	1.27	0.07	--	--	340	>200.5
S171975(青出)	<5	0.088	0	无	26	6.86	0.88	0.04	--	<0.05	<0.02	0.50	--	0	0
S171976(荔原)	35	81.3	0	含少许异物	26	7.08	3.92	0.34	0.08	1.26	0.09	--	--	190	>200.5
S171977(荔出)	<5	0.091	0	无	26	6.71	1.04	0.03	--	<0.05	<0.02	0.17	--	0	0
S171978(金原)	20	60.8	0	含少许异物	26	7.08	3.20	0.33	0.09	0.95	0.09	--	--	150	>200.5
S171979(金出)	<5	0.140	0	无	26	6.98	0.80	0.04	--	<0.05	<0.02	0.15	--	0	0
S171980(青原)	25	50.2	0	含少许异物	26	7.09	2.24	0.39	--	1.39	0.04	--	--	270	>200.5
S171981(青出)	<5	0.069	0	无	26	6.97	0.80	0.06	--	<0.05	0.02	0.50	--	0	0

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制

[illegible]